

ROLLS R-SERIES, G-SERIES & S-SERIES LFP DROP-IN BATTERY OPERATING MANUAL

Rolls

BATTERY ENGINEERING



Recommended safety, installation, operation and troubleshooting procedures for Rolls R-Series, G-Series and S-Series 12V, 24V, 36V, and 48V LFP (Lithium Iron Phosphate) drop-in batteries.



**RENEWABLE
ENERGY**



MARINE



**MOTIVE
POWER**

TABLE OF CONTENTS

02	ROLLS R-SERIES, G-SERIES & S-SERIES LFP DROP-IN BATTERIES
03	VERSION HISTORY/CHANGELOG
05	STORAGE
05	INSTALLATION
05	WAKING UP THE BATTERY
06	TERMINAL TORQUE
06	CABLE CONNECTIONS
07	BMS PROTECTION SUMMARY
08	CONNECTION LIMITS
08	CONNECTING IN SERIES
08	SERIES CONFIGURATIONS
09	CONNECTING IN PARALLEL
10	BATTERY VOLTAGE - CONNECTING IN SERIES/PARALLEL
11	BLUETOOTH/APP CONNECTIVITY
12	ADDITIONAL G-SERIES & S-SERIES FEATURES
15	BATTERY CHARGING
16	CHARGING GUIDELINES
17	CHARGING SOURCE: ALTERNATOR
17	CHARGING SOURCE: LEAD-ACID BATTERY CHARGER
18	1-STAGE CHARGING - CC (CONSTANT CURRENT)
19	2-STAGE CHARGING - CC/CV (CONSTANT CURRENT/CONSTANT VOLTAGE)
20	3-STAGE CHARGING - LEGACY LEAD-ACID SYSTEMS, INVERTER/CHARGER HARDWARE
21	CHARGING TEMPERATURE
22	RECYCLING
22	LFP GLOSSARY
24	APPENDIX A: G-SERIES & S-SERIES BMS QUICK ERROR CODE REFERENCE
25	APPENDIX B: BMS PROTECTION SUMMARY REFERENCE
26	APPENDIX C: ROLLS GOLF & LIGHT EV LFP BATTERY SOC INDICATOR INSTALLATION GUIDE
27	PINOUT
27	INSTALLATION OF THE SOC INDICATOR
28	INSTALLATION OF AN IN-LINE POWER SWITCH
32	CONTACTS
33	NOTES



Para ver la versión en español, haga clic aquí.
O consulte nuestro sitio web.



ROLLS R-SERIES, G-SERIES & S-SERIES LFP DROP-IN BATTERIES

Rolls R-Series, G-Series, and S-Series drop-in Lithium Iron Phosphate (LFP/LiFePO₄) batteries are an ideal replacement for traditional lead-acid batteries of equivalent size & capacity and offer the same quality, reliability and performance found in other Rolls Battery products.

This manual provides detailed instructions for safe and proper installation, operation, and care of Rolls R-Series, G-Series and S-Series LFP drop-in battery models. Please read carefully to clearly understand the operating instructions and any potential safety risks prior to installation.

Failure to install or use this battery as instructed may result in damage to the product that may not be covered under the manufacturer warranty. See warranty terms and conditions for full details.

NOTE: This manual offers installation, charging, and troubleshooting guidance specific to Rolls **R-Series, G-Series and S-Series LFP** drop-in lithium batteries.

See Rolls S24-2800LFP & S48-6650LFP ESS Battery Operating Manual for usage instructions specific to Rolls S24-2800LFP ESS and S48-6650LFP ESS (Energy Storage System) models.	
See Rolls S48-100LFP ESS Battery Operating Manual for usage instructions specific to that 19" rack mount ESS model.	
See Rolls S48-100LFP STACK-LV Battery Operating Manual for usage instructions specific to that stackable ESS model .	

THIS DOCUMENT IS NOT APPLICABLE TO THE FOLLOWING MODELS

51.2V LFP ESS Models
(S48-100LFP ESS)



51.2V LFP ESS STACK Models
(S48-100LFP STACK-LV)



Nominal voltage of an LFP battery differs from equivalent lead-acid batteries.

LFP BATTERY	LEAD-ACID BATTERY
Cell Voltage = 3.2V	Cell Voltage = 2.0V
Battery Nominal Voltage 12.8V (4 cells)	Battery Nominal Voltage 12.0V (6 cells)
Battery Nominal Voltage 25.6V (8 cells)	Battery Nominal Voltage 24.0V (12 cells)
Battery Nominal Voltage 38.4V (12 cells)	Battery Nominal Voltage 36.0V (18 cells)
Battery Nominal Voltage 51.2V (16 cells)	Battery Nominal Voltage 48.0V (24 cells)

VERSION HISTORY/CHANGE LOG

REV.	CHANGELOG	AUTHOR/EDITOR	DATE
1.0	Release Version - R-Series Revision	Jordan Torrealba	2021/12/14
2.0	Release Version: R-Series & S-Series Revision	Jordan Torrealba	2023/07/25
3.0	Release Version: R-Series, G-Series & S-Series Revision	Jordan Torrealba	2025/12/25
4.0	SOC Monitor and in-line switch installation	Jordan Torrealba	2026/05/05



WARNING: Explosion, Electrocution, or Fire Hazard

- A battery can present a risk of electric shock, burns, fire, or explosion.
- Ensure cables are properly sized for the system current and cable runs are as short as possible.
- Ensure cables between batteries are of equal length, reducing line inductance and voltage spikes, which can damage the BMS.
- Ensure adequate airflow around batteries and that they are clear of debris, 2cm/1" spacing is recommended.
- Never smoke or allow a spark or flame near the batteries.
- Always use insulated tools.
- Avoid dropping tools onto batteries or other exposed electrical parts.
- Prolonged exposure to cold temperatures can cause significant damage to batteries, proportional to charge and discharge current:
 - Never charge an R-Series drop-in LFP battery or bypass the heating controls on an S-Series drop-in LFP battery below 0°C (32°F).
 - Never discharge an R-Series or S-Series drop-in LFP battery below -20°C (-4°F).
- Never charge a battery with a deformed or bulging case.
- Do not expose a Rolls drop-in LFP battery to heat more than 60°C (140°F) during operation, and do not store for extended periods of time above 45°C (113°F). Do not incinerate or expose to open flame.
- If a battery must be decommissioned, always remove the grounded terminal from the battery first. Make sure all connected devices are shut down.
- When installing, leave adequate clearance between batteries 2cm/1" is recommended.
- When replacing batteries, use the same make, model, and quantity of batteries.
- Do not mix old and new batteries, or batteries with different nominal voltages.
- Avoid dropping batteries during the installation process.
- Do not dismantle or remove the battery components.
- Battery maintenance should be carried out by qualified personnel under the guidance of Rolls Battery.

STORAGE

Rolls LFP batteries have operating and storage temperature limitations. These should be followed to ensure the battery remains in good working order and to prevent the possibility of cell and component damage or failure. Rolls LFP batteries include cylindrical or prismatic cell types as well as various electronic components. As a result, storage temperature limits may vary by battery model as outlined.

For optimal performance, Rolls recommends storing LFP batteries in ambient temperatures between -5°C (23°F) and 45°C (113°F).

Rolls manufacturer warranty terms for R-Series, G-Series & S-Series LFP drop-in batteries also require storage in temperatures above -5°C (23°F) and no higher than 45°C (113°F) in line with battery component limitations. Product damage or failure due to extended exposure to temperatures at or outside this range would not be covered under warranty.

STORAGE	TEMPERATURE RANGE
RECOMMENDED	-5°C (23°F) to 45°C (113°F)
COMPONENT LIMIT	-5°C (23°F) to 45°C (113°F)

Rolls R-Series, G-Series & S-Series LFP drop-in batteries do self-discharge and should be charged once per year, at minimum, when stored for extended periods. For temperatures above 40°C (104°F) the battery should be charged every 3 months as self-discharge rates increase in warmer temperatures. Do not store Rolls S48-100LFP STACK-LV batteries at temperatures above 55°C (131°F).

In cold climates, charge/discharge the battery to between 60-80% state of charge, disconnect from any external system, and store the battery off site, above -5°C (23°F).

For seasonal applications, Rolls R-Series, G-Series & S-Series LFP drop-in batteries should not be left connected to an offline system or disconnected and stored in a space where ambient temperatures may fall below the -5°C (23°F) or above 45°C (113°F).

NOTE: Ensure the breaker and BMS are **OFF** during storage.

INSTALLATION

Rolls R-Series, G-Series & S-Series LFP drop-in batteries may be installed in any orientation* (except upside down) as required by the application. Rolls LFP drop-in batteries must be installed in an indoor space and out of direct sunlight.

*Front Terminal (FT) models may be installed upright or on one side only due to placement of internal components. Refer to the product label on the battery to identify which side of the battery must be facing up.

All installations should consider ambient temperature range. If installed in a region with freezing temperatures or extreme heat, special care should be given. **Rolls R-Series & G-Series LFP drop-in batteries cannot be charged below 0°C (32°F), nor discharged below -20°C (-4°F)** and doing so will severely degrade the internal cells. Similarly, operation above 55°C (131°F) will negatively impact longevity, performance, and safety. Rolls S-Series LFP drop-in batteries feature internal heating to compensate for reduced temperatures but are still limited in the external temperatures they can tolerate. Refer to the datasheet or label of your specific model for accurate information.

Rolls metal case G-Series LFP 48V golf & light EV models equipped with CAN bus port include cabling and a state of charge (SOC) indicator that may be mounted on a golf cart dash, etc.

Refer to the installation instructions in **APPENDIX C: ROLLS GOLF & LIGHT EV LFP BATTERY SOC INDICATOR INSTALLATION GUIDE**

WAKING UP THE BATTERY

If you have just received your battery, it may have entered a low power sleep mode during transit. In this state, the Bluetooth receiver will be off, and the apparent voltage will be between 2V-10V, waiting to sense an external device. For R-Series LFP drop-in models, connect a charger or load to “wake up” that unit and enable charging, discharging, and a Bluetooth connection. To wake up a G-Series or S-Series LFP drop-in battery, do this, or press and hold the reset button located below the onboard screen.

TERMINAL TORQUE

Terminal connections must be properly torqued. Rolls R-Series, G-Series & S-Series LFP drop-in batteries using M8 fasteners should be torqued to **10-12Nm**.

DO NOT OVERTORQUE: In the event of a damaged terminal, do not attempt to repair the terminal. Do not use the battery if the recommended torque cannot be met.

CABLE CONNECTIONS

All cable connections should be adequately sized, insulated, and undamaged. Connectors should be clean and properly mated with the battery terminals to ensure a secure and low resistance connection. Terminal connections should be torqued to the recommended specification in TERMINAL TORQUE. Although Rolls R-Series, G-Series and S-Series LFP drop-in batteries do not require maintenance such as cell inspection & watering, routine inspection of cabling and terminal connections should be performed semi-annually. Double check torque specification and that lugs cannot be rotated after installation. If the batteries are installed in a high vibration environment, this should be done more frequently.

AMPERAGE	25	30	40	55	75	95	130	150	170	195	260
WIRE GAUGE	14	12	10	8	6	4	2	1	1/0	2/0	4/0

NOTE: Undersized or improperly insulated cables may lead to cable and/or battery damage, charging issues, terminal heating, or fire. The gauge table above is provided for reference only. Always refer to the connector and wire manufacturers' specifications prior to purchase and installation.

Like lead-acid batteries, connecting devices (like batteries, inverters, chargers, MPPTs, etc.) at different voltages can result in large current spikes and arcing. Sparking may occur if you are connecting a power supply or charger with high output capacitance, or a discharged inverter with high input capacitance, as the battery rapidly charges the components in the device. Connecting terminals quickly and decisively is recommended for the least component wear and tear or using in-line overcurrent protection devices such as an open breaker, to eliminate arcing.

BMS PROTECTION SUMMARY

Rolls LFP drop-in batteries include a built-in battery management system (BMS) which offers protection in conditions where the battery voltage, current or operating/cell temperature may be unsafe or damaging for the internal cells. The switch architecture of the BMS allows charge and discharge to be stopped independently. Under these undesirable operating conditions, the internal BMS can independently interrupt charge or discharge, or disconnect it fully, as required.

BATTERY LIMIT	PROTECTION	RESET METHOD	COMMENTS
Cell/Pack Overvoltage	Charge Interruption	Automatic reset after time delay or discharge	If occurring more than 3 times in 2 minutes, discharge is required
Cell/Pack Undervoltage	Discharge Interruption	Automatic reset after time delay or charge	If occurring more than 3 times in 2 minutes, charge is required
Extended Pack Undervoltage (Stored While Empty)	Battery Cannot be Recovered	Always charge LFP drop-in batteries within 72 hours of full discharge	
Pack Overcurrent or Short Circuit	Charge & Discharge Interruption	Automatically reset after time delay	If occurring more than 3 times in 2 minutes, charge is required
High temperature at BMS or Cell*	Charge & Discharge Interruption	Automatically reset after cooling	BMS will display alarm when approaching disconnect
Low temperature at BMS or Cell*	Charge Interruption	Automatically reset after warming	BMS will display alarm when approaching disconnect
Extreme low temperature at BMS or Cell	Charge & Discharge Interruption	Automatically reset after warming	BMS will display alarm when approaching disconnect
(G-Series & S-Series only) Secondary Overcurrent Protection	Charge & Discharge Interrupted External fuse is blown.	Replace fuse	Secondary protection is also recommended for all R-Series batteries

*Temperatures outside of the ideal operating range require a reduction in charge/discharge current for optimal battery life.

The BMS also has cell-balancing functionality to balance each internal cell to the same state-of-charge, enabling the full pack capacity. However, this is not sufficient to balance severely imbalanced cells with a substantial state-of-charge (SOC) difference, see **BATTERY VOLTAGE - CONNECTING IN SERIES/PARALLEL**.

CONNECTION LIMITS

LFP MODELS	MAXIMUM UNITS SERIES CONNECTION	MAXIMUM UNITS PARALLEL CONNECTION
12 VOLT LFP	4 (48V System)	4 (6 if not series connected)
24 VOLT LFP	2 (48V System)	4 (6 if not series connected)
36 VOLT LFP	1 (36V System)	6 (no series connection)
48 VOLT LFP	1 (48V System)	6 (no series connection)

NOTE: Rolls R-Series, G-Series & S-Series drop-in models cannot be mixed. When connecting in series or parallel, Rolls LFP models should only be combined in the same capacity and voltage, from the same product line.

NOTE: For lithium batteries, parallel batteries are preferred over series strings. Rolls R-Series, G-Series & S-Series drop-in models perform best when connected in parallel. Choosing drop-in batteries at a voltage to match your external equipment is recommended.

CONNECTING IN SERIES

Rolls R-Series, G-Series and S-Series 12V and 24V LFP batteries may be combined in series strings to achieve higher operating voltages by connecting the positive terminal of one battery to the negative terminal of the next battery. Don't connect different voltages in series. For example, do not connect a 12V and 24V battery to reach 36V, use three (3) 12V batteries instead, or a single 36V battery.


NOTE: 36V and 48V models may **NOT** be connected in series.

SERIES CONFIGURATIONS


For 24V Applications	12V batteries in series - Two (2)	$2 \times 12.8V = 25.6V$
	24V battery in series - One (1)	$1 \times 25.6V = 25.6V$
For 36V Applications	12V batteries in series - Three (3)	$3 \times 12.8V = 38.4V$
	36V battery in series - One (1)	$1 \times 38.4V = 38.4V$
For 48V Applications	12V batteries in series - Four (4)	$4 \times 12.8V = 51.2V$
	24V battery in series - Two (2)	$2 \times 25.6V = 51.2V$
	48V battery in series - One (1)	$1 \times 51.2V = 51.2V$

NOTE: Do not connect batteries in strings above 48V nominal.

Example 24V Configuration: Two 12V batteries in series



Example 48V Configuration: Four 12V batteries in series




CONNECTING IN PARALLEL

You may combine Rolls 12V or 24V LFP drop-in batteries of the same model together in up to four (4) parallel strings to increase system capacity. If no series connections are made, up to six (6) LFP drop-in batteries of the same model may be connected in parallel.

Refer to the example below showing eight (8) 12V LFP drop-in batteries connected in a 48V configuration; four (4) connected in series and two (2) parallel strings (4S2P). Up to four (4) 48V parallel strings of 12V or 24V LFP drop-in models may be connected. Parallel string configurations greater than 48V in series, four in parallel (4S4P or 2S4P) are not supported currently.

NOTE: When connecting parallel strings of Rolls R-Series, G-Series or S-Series LFP drop-in batteries of the same model, the recommended current limit increases proportional to the number of parallel strings.

48V Configuration: Connecting Eight (8) x 12V LFP Drop-in batteries Four (4) in series with two (2) parallel series strings



NOTE: Strings are independent. External connections should be staggered, i.e., the positive lead is connected to string one, whereas the negative lead is connected to string two.

NOTE: Keep cabling the same resistance (gauge and length) between batteries and strings to ensure proper current sharing. Attempt to minimize length to reduce the magnitude of inductive voltage spikes at the battery.

CAUTION

- Failure to follow the following safety instructions may result in personal injury or damage to the equipment.
- Rolls R-Series, G-Series and S-Series LFP drop-in batteries should be fully charged in parallel before connecting for series cycling, see below.
- Do not connect more than four (4) strings of series-connected batteries in parallel.

BATTERY VOLTAGE - CONNECTING IN SERIES/ PARALLEL

For initial balancing prior to connecting batteries in series, each battery should be connected in parallel (you may connect above the maximum of four (4) batteries in parallel, but not for regular cycling) and fully charged (or charged individually) using a 2-stage CC/CV charger at a reduced CV voltage corresponding to the low end of the acceptable charge range (see below), leaving the battery at the absorption/CV voltage for at least 24 hours.

SYSTEM VOLTAGE	12V NOMINAL	24V NOMINAL	36V NOMINAL	48V NOMINAL
RECOMMENDED INITIAL BALANCING VOLTAGE	14.0V	Balance initially at 12V NOMINAL		

If you are unable to charge the batteries individually, the voltage of each battery should be within 30mV (0.03V) before putting them in service. This will minimize the severity of a charge imbalance between batteries which results in reduced pack capacity. LFP batteries, even those with similar open circuit voltages may be at drastically different SOC, due to the flat relationship between open circuit voltage and SOC for LFP cells.

Although the BMS provides over-voltage protection to each cell, developing a charge imbalance between batteries is still possible. Disconnecting and fully charging each battery individually once per year if 1 or 2 parallel strings is used, or every 6 months in systems with 3 or 4 parallel strings, is recommended. If the batteries are cycled frequently at high charge/ discharge currents this may be done more often.

Absorption time can also help with balancing. For a single string, absorption times of 20-30 minutes is recommended, or up to 60 minutes for 4 strings. See **3-STAGE CHARGING - LEGACY LEAD-ACID SYSTEMS, INVERTER/CHARGER HARDWARE** for more information on using legacy chargers with R-Series, G-Series & S-Series LFP.

BLUETOOTH/APP CONNECTIVITY




WAKING UP THE BATTERY

This is also discussed above in **WAKING UP THE BATTERY**.

If you have just received your battery, it may have entered a low power sleep mode during transit. In this state, the Bluetooth will not broadcast a signal your device can connect to. For R-Series LFP drop-in models, connect a charger or load to “wake up” that unit and enable a Bluetooth connection. To wake a G-Series or S-Series LFP drop-in battery, press the reset button located below the onboard screen.

ESTABLISHING A CONNECTION



Rolls LFP Connect app allows users to connect and view battery-related status information via Bluetooth connection with Rolls LFP drop-in batteries. To initiate a new battery connection, select “Add Battery”. Using Bluetooth, your device will then search for batteries within signal range. Available batteries will be listed as shown above. If your battery cannot be found, try waking up the battery (above), and ensure no devices which may block or interfere with a wireless signal are nearby. All batteries within range will be listed by the app. If you have multiple batteries to connect to, consult the lasered serial number on the side of the unit to keep track of each battery. Click “Add” for the selected batter(ies). Consider installing them in ascending order, or an order you can easily remember. Bluetooth names may not be sequential but will be unique. Once connected, a battery may be selected from the Connected Batteries list to view additional details.

DASHBOARD & SUPPORT SCREENS

The main Dashboard screen has a display of estimated state-of-charge (SOC), the connected battery, battery voltage, current, internal cell temperature, and any active fault codes.

Using the app, you can submit a support ticket directly to our service team, you will receive email confirmation and be contacted by us regarding your issue. Please fill this out with as much relevant information as you can to better aide our support personnel.

10:27 AM40%

<Submit a Ticket

Name

*Required Field

Email

*Required Field

Phone Number

*Required Field

Subject

*Required Field

ADDITIONAL G-SERIES & S-SERIES FEATURES DISPLAY

12.8 V
75 %

Regular State: Voltage, SOC, Heating (S-Series only), Bluetooth Status

12.8 V
ER 1

Error State: Error Code is displayed.

BMS ERROR CODE REFERENCE (Repeated in APPENDIX A)		
CODE	DESCRIPTION	ACTION
ER0	Other/Unknown	Refer to App, contact support@rollsbattery.com
ER1	Over Voltage	Discharge Battery
ER2	Under Voltage	Charge Battery
ER3	Over Temperature	Battery is too hot. Consider ambient temperature, insulation and adequate spacing between batteries.
ER4	Under Temperature	Battery is too cold. Consider ambient temperature and insulation. Check heating status as the battery may require additional time to reach charging temperature.
ER5	Charge Over Current	Adjust charger setpoints to limit below the maximum current specified for the battery model.
ER6	Short Circuit/Discharge Overcurrent	Adjust charger setpoints to limit below the maximum current specified for the battery model. Use caution on install to avoid accidentally short
ER7	Imbalance	If repeated imbalance occurs, reduce charger setpoints and leave at CV voltage to rebalance cells.
ER8	Switch Over Temperature	Potentially address cooling/insulation, current, and external temperature. If this continues at currents below specification, contact Technical Support.

STATUS BUTTON

G-Series & S-Series LFP drop-in models (in ABS case) feature a button located below the integrated screen on the top of the case. This button enables the user to quickly view battery voltage and estimated state-of-charge (SOC) without connecting via the LFP Connect app or using a multimeter. The button may also be used to quickly put the battery into or out of sleep mode, allowing added peace of mind when receiving and storing your S-Series LFP battery.

DESCRIPTION	ACTION
Short Press	Turn on display (SOC and voltage) and Bluetooth search.
Long Press (3 Seconds)	Put battery into or out of sleep/storage mode.

FUSE ACCESS

S-SERIES FUSE REFERENCE				
ROLLS G-SERIES & S-SERIES BATTERY	RATINGS		PART NUMBER	
	CURRENT	VOLTAGE	LITTELFUSE	GENERIC
S24-50 LFP	100A	58V	142.5631.6102 (M5)	ANS - 100 (M5)
G24-40LFP S12-100LFP	200A	58V	142.5631.6202 (M5)	ANS - 200 (M5)
G48-45LFP S24-100LFP	200A	70V	0998200.UX-2M8 (M8)	ANS - 200 (M8)
G36-50LFP G48-70LFP S12-135LFP S12-150LFP S24-150LFP	300A	70V	0998300.UX-2M8 (M8)	ANS - 300 (M8)
G12-450LFP G24-130LFP G36-95LFP S12-200LFP S12-300LFP	400A	70V	0998400.UX-2M8 (M8)	ANS - 400 (M8)

FUSE REPLACEMENT PROCEDURE

If the fuse has blown in a G-Series or S-Series LFP drop-in model it is likely that there is a secondary effect which has caused this to occur. This might be caused by an imbalance resulting in charge equalization between batteries (at very high currents), a component drawing too much current, or a BMS issue causing the secondary protection to be necessary. If you have checked all connected devices, the balance of connected series strings or batteries, and the battery BMS through the LFP Connect app, and the fuse must be replaced in a G-Series or S-Series drop-in model, the following procedure should be followed:

1. Remove the fuse access cover on the top of the battery.
2. Ensure the fuse is, in fact, fused by visually inspecting the fusible link window, and/or by using a continuity tester.
3. Using a battery isolator switch or disconnecting the positive terminal, remove the battery from the system.
4. Remove the fuse bolts from the fuse and remove the fuse.
5. Replace the fuse and reconnect the fuse bolts, using proper torque:
 - a. M8 (ANM) 10-12nm.
 - b. M5 (ANS) 6-8nm.

NOTE: The fuse is not directional. However, installing with the window facing up is recommended for easy inspection.

6. Reconnect the battery isolator or positive terminal connection following existing system setup procedures.

G-SERIES & S-SERIES LFP - UPGRADED CONSTRUCTION

Rolls G-Series and S-Series LFP drop-in models advance traditional LFP battery construction, repairability, and technology by replacing internal wiring with robust busbars and upgrading soldered BMS connections to secure screw terminals. The accessible case design enhances serviceability, while externally mounted fuses improve safety. An external display simplifies error identification across large battery banks, and the convenient on/off button allows for easy wake-up from sleep mode.

G-SERIES & S-SERIES LFP - CASE ACCESS

Accessing case internals without authorization will void the manufacturer warranty, and doing so is not recommended as it will expose conductors that bypass the BMS and safety features of the battery. The case cover on Rolls G-Series and S-Series LFP drop-in models is designed to be externally accessible with integrated fasteners to allow servicing solely by the manufacturer or an authorized Rolls Battery technician.

BATTERY CHARGING

Although a lithium-specific charger is recommended, Rolls R-Series, G-Series and S-Series LFP drop-in models are compatible with many common lead-acid battery chargers which operate at the same nominal voltage of the pack. The acceptable charge voltage range and recommended & maximum continuous charge currents are specified on the product label for reference.

Rolls R-Series, G-Series and S-Series LFP drop-in batteries may cycle or be stored in a partial state of charge (PSOC). Rolls R-Series, G-Series and S-Series LFP drop-in batteries should be cycled from 100% state-of-charge (SOC) [0% depth of discharge (DoD)], to 20% SOC [80% DOD] for optimal cycle life. To prevent over-discharge, the BMS will disconnect the battery when the low voltage cut-off is reached, protecting the battery from over-discharge.

NOTE: Chargers that require the detection of voltage at the battery terminals to charge may fail to wake the R-Series, G-Series and S-Series LFP drop-in battery from a state of under-voltage protection or sleep.

NOTE: LFP cells do not need maintenance charges like equalization, pulse charge, overcharge, or any others typically recommended or required for lead-acid batteries.




NOTE: The recommended and maximum continuous charge & discharge currents are specific to each R-Series, G-Series and S-Series LFP drop-in model. These are determined by capacity, cell and BMS technology. Model-specific information is provided on the product label.

CHARGING GUIDELINES

Rolls R-Series, G-Series and S-Series LFP drop-in batteries may be charged in a 1, 2, or 3-Stage charge profile, shown below. The specifics and recommended setpoints for these charge regimes are explained in this section, with the recommended charge profile being a 2-Stage charge.

Representation of 1, 2, and 3-Stage Charging Profiles



Representation of recommended 2-Stage Constant Current/Constant Voltage (CC/CV) charging. The dotted line represents the transition from CC to CV when the voltage limit is reached. Once the battery reaches the constant voltage limit, the battery is held by the charger at this voltage until the current decreases to 0.05C. At this point the battery is at 100% state-of-charge (SOC). Any current continuing to flow in the float stage is attributable to balancing activity of the BMS.

CHARGING SOURCE: ALTERNATOR

Alternators in automotive, marine, and RV applications are typically not designed to tolerate the sudden load changes that can occur during a rapid open-circuit event. This condition may occur if the battery bank disconnects due to a fully charged state, temperature limit, or overcurrent protection triggered by the BMS. When the load is suddenly removed, the alternator's field excitation can produce a high-voltage transient at the output, potentially damaging internal rectifiers or voltage regulation circuitry. To mitigate this risk, it is recommended to install an alternator protection device or intermediary DC charge controller to isolate and protect the alternator in the event of a battery disconnection.

CHARGING SOURCE: LEAD-ACID BATTERY CHARGER

Customers may choose to replace lead-acid batteries with lithium models. Most lead-acid battery chargers may be used to charge Rolls R-Series, G-Series & S-Series LFP drop-in models so long as the charger is properly configured to operate within the recommended charge current and voltage limits.

The pre-programmed voltage settings for AGM or OPzV GEL models may be in line with the recommended LFP drop-in charge voltage settings and may sometimes be used if direct voltage control is not possible for your charger. However, flooded batteries often require higher charge voltage settings than sealed models. If left configured for charging flooded batteries, the higher charge voltage can trigger the BMS to restrict charging to protect the battery, effectively resulting in a 1-stage charge. If this occurs repeatedly, or the charger cannot be configured at a lower charge voltage, it may be necessary to replace the charger for optimal balancing.

1-STAGE CHARGING - CC (CONSTANT CURRENT)

When charging with a single-stage constant current charger, charge at the recommended charge current, by operating temperature, until the battery reaches its termination voltage.

1-STAGE CHARGE PROFILE			
Recommended Charging Current for Optimal Life			
Temperature Range		Optimal Current	
-20-0°C (-4-32°F)		≤ 0.1C (S-Series only) 	
0-10°C (32-50°F)		≤ 0.2C	
10-35°C (50-95°F)		≤ 0.5C	
35-55°C (95-131°F)		≤ 0.2C	
Maximum Continuous Charging Current			
R-Series	0.5C	G & S-Series	1C*

*Up to a maximum of 200A.

SYSTEM	12V NOMINAL	24V NOMINAL	36V NOMINAL	48V NOMINAL
TERMINATION VOLTAGE	14.4V	28.8V	43.2V	57.6V

NOTE: 1-Stage CC Charging may be required if charging from a source which is not efficient to run at lower power, such as a generator. However, it may only charge the battery to 90-95% SOC and provide very little time to balance cells. For these reasons, 2-Stage CC/CV charging is recommended to ensure the battery reaches full SOC.

2-STAGE CHARGING - CC/CV (CONSTANT CURRENT/CONSTANT VOLTAGE)

When charging with a two-stage constant current/constant voltage (CC/CV) charger, charge at the recommended charge current, by operating temperature, until the battery reaches the "absorption" voltage or constant voltage (CV) limit. The charger then holds the battery at CV until the charge current decreases to $\leq 0.05C$ (termination current).

The recommended absorption (constant voltage) voltage is shown below. If the charger has a pre-set voltage setting or cannot be programmed, an absorption voltage in the range below is also acceptable. Note: lower voltage will lead to longer charge times.

2-STAGE CHARGE PROFILE			
Recommended Charging Current for Optimal Life			
Temperature Range		Optimal Current	
-20-0°C (-4-32°F)		≤ 0.1C (S-Series only) 🔥	
0-10°C (32-50°F)		≤ 0.2C	
10-35°C (50-95°F)		≤ 0.5C	
35-55°C (95-131°F)		≤ 0.2C	
Maximum Continuous Charging Current			
R-Series	0.5C	G & S-Series	1C*

*Up to a maximum of 200A.

SYSTEM	12V NOMINAL	24V NOMINAL	36V NOMINAL	48V NOMINAL
RECOMMENDED ABSORPTION VOLTAGE	14.4V	28.8V	43.2V	57.6V
ABSORPTION RANGE (ACCEPTABLE)	14.0V - 14.6V	28.0V - 29.2V	42.0V - 43.8V	56.0V - 58.4V
TERMINATION CURRENT	$\leq 0.05C$			

NOTE: If charge time is not a concern within your system architecture, reducing the absorption voltage will increase charge time, but allows the BMS more time to ensure all cells remain balanced. As batteries age, small changes in manufacturing or due to uneven wear may present themselves, requiring more time to maintain balance.

3-STAGE CHARGING - LEGACY LEAD-ACID SYSTEMS, INVERTER/CHARGER HARDWARE

When programming an inverter/charger or charge controller equipment using a 3-stage charge sequence (2-stage with an additional “float voltage” after the charge is terminated), the following charging parameters should be programmed to properly charge Rolls 12V, 24V, 36V & 48V R-Series, G-Series and S-Series LFP drop-in batteries:

3-STAGE CHARGE PROFILE			
Recommended Charging Current for Optimal Life			
Temperature Range		Optimal Current	
-20-0°C (-4-32°F)		≤ 0.1C (S-Series only) 🔋	
0-10°C (32-50°F)		≤ 0.2C	
10-35°C (50-95°F)		≤ 0.5C	
35-55°C (95-131°F)		≤ 0.2C	
Maximum Continuous Charging Current			
R-Series	0.5C	G & S-Series	1C*

*Up to a maximum of 200A.

SYSTEM	12V NOMINAL	24V NOMINAL	36V NOMINAL	48V NOMINAL
BULK to ABS VOLTAGE	14.4V	28.8V	43.2V	57.6V
ABSORPTION VOLTAGE	14.4V	28.8V	43.2V	57.6V
ABS to FLOAT	≤0.05C	≤0.05C	43.2V	≤0.05C
FLOAT VOLTAGE	13.6V	27.2V	40.8V	54.4V

Temperature Compensation: If the inverter/charger or charge controller uses temperature compensation this should be turned off when charging Rolls R-Series and S-Series models. Turn off the temperature compensation settings and disconnect the sensor to ensure the correct voltage regulation from the charging device.

Equalization: Equalization should never be used; elevated charge voltages are unacceptable for LFP batteries and will simply lead to the BMS disconnecting the charging path. It should be turned off, or the equalization voltage setpoint should be reduced to the appropriate system float voltage, above.

Some charger models may require additional firmware, programming, or parameters. Please contact your inverter/charger or charge controller manufacturer for assistance with these settings, if required.

CHARGING TEMPERATURE

Due to the chemistry of LFP cells, these batteries cannot accept high charge current at low operating temperatures without cell damage and permanent capacity loss.

Rolls R-Series & G-Series LFP drop-in batteries may be safely charged between 0°C to 55°C (32°F to 131°F). However, because cycle wear is accelerated below 10°C (50 °F) the charge should be limited to 0.2C (20% of battery capacity) for optimal longevity. Similarly, at high temperatures, charge current should be limited to $\leq 0.2C$ when operating at temperatures from 35°C to 55°C (95°F to 131°F) as noted below.

Rolls S-Series LFP drop-in batteries may be charged at lower temperatures due to their internal heating which allows them to compensate for external temperatures down to as low as -20°C. If the batteries are typically charged at low temperatures [-20-0°C (-4-32°F)], proper insulation is required to keep the batteries at their warmed temperature.

To maintain optimum performance and durability of Rolls R-Series & G-Series LFP batteries, the following charge current limits should be followed:

TEMPERATURE	RECOMMENDED CHARGE CURRENT
0-10°C (32-50°F)	$\leq 0.2C$
10-35°C (50-95°F)	$\leq 0.5C$
35-55°C (95-122°F)	$\leq 0.2C$

NOTE: Due to the internal chemistry, LFP batteries may be discharged at lower temperature than they may be charged. At low temperatures, between -20°C and 0°C, R-Series & G-Series LFP drop-in batteries will still be effective in discharging. However, no energy may be put into the batteries.

The recommended and maximum continuous charge current is specified for each Rolls R-Series, G-Series and S-Series LFP drop-in model as a function of capacity, cell and internal BMS. This information is noted in the model specifications and on the battery label.

Some G-Series LFP models feature an upgraded BMS selected specifically for golf & motive power applications, allowing up to 2C / 10-minute peak discharge current. This is noted, where applicable, on the battery label.

RECYCLING

Rolls R-Series, G-Series and S-Series LFP drop-in batteries should be properly disposed of at an authorized lithium recycling facility. Do not remove product labels and/or recycling information from the battery case.

The battery should be fully discharged before disposal. To prevent a possible short circuit or explosion, the terminals should be covered with a protective cap or non-conductive tape before disposal.

LFP GLOSSARY

AMP, AMPERE

Unit of electrical current. Abbreviated "A".

AMP-HOUR

Unit of electrical energy, one amp of current flowing for one hour. Abbreviated "Ah".

BMS (BATTERY MANAGEMENT SYSTEM)

The BMS, or Battery Management System, is an electronic device which protects the cells inside a battery. The BMS used in Rolls R-Series and S-Series LFP batteries protects them from unsafe voltage, current, and temperature conditions. It keeps cells balanced to ensure pack capacity is maintained. A BMS is required for any lithium-ion battery system with series-connected cells due to the safety requirements and performance characteristics of the cells.

C-RATE

Battery charge and discharge rates are often described as a "C-Rate", defined as:

$$C - Rate = \frac{(Rated Capacity)}{(Charge/Discharge Current)}$$

For example, if a 100Ah battery was charged at 50A, but discharged at 100A, it would be charged at a rate of C/2 and discharged at a rate of C. This rate is independent of system voltage.

CELL

A single battery, independent of chemistry. Each cell is at the base voltage for the given chemistry; 2.0V for flooded lead acid, 3.2V for lithium iron phosphate. Many cell form factors exist, resulting in different capacities and performance characteristics. These may be combined in series to form a battery of higher voltage.

CC/CV (CONSTANT CURRENT / CONSTANT VOLTAGE)

The typical charge profile of a LFP battery. CC/CV or Constant Current/Constant Voltage charging is a 2-stage charge, first at constant current until the battery voltage reaches a given limit, and then at constant voltage as the current accepted by the battery naturally reduces until the battery is full.

CYCLE

A "cycle" is a somewhat arbitrary term used to describe the process of discharging a fully charged battery down to a particular state of discharge. For Rolls R-Series Batteries, a cycle is defined as 90% depth of discharge, or going from full charge down to 10% state-of-charge.

CYCLE LIFE

The total energy throughput of a battery, defined in terms of the amount of equivalent charge/discharge cycles it can withstand before its effective capacity is reduced to a certain amount, usually 80% of original/rated capacity.

LFP (LITHIUM IRON PHOSPHATE)

LFP, or Lithium Iron Phosphate is a specific type of Lithium-ion battery chemistry. Referring to the cathode material of the battery, this chemistry is characterized by its long cycle life, long calendar life and safety, in overcharge conditions, compared to other battery chemistries.

SOC (STATE-OF-CHARGE)

State-of-charge (SOC) represents the fullness of the battery from 0%-100%.

VOLT

The unit of electrical potential or "pressure". For the LFP cell chemistry, these are multiples of 3.2V, sometimes simplified to 12V, 24V and 48V to match with compatible lead-acid systems.

APPENDIX A: G-SERIES & S-SERIES BMS QUICK ERROR CODE REFERENCE

CODE	DESCRIPTION	ACTION
CODE	LFP BATTERY	
ER0	Other/Unknown	Refer to LFP Connect app. Contact support@rollsbattery.com
ER1	Over Voltage	Discharge battery.
ER2	Under Voltage	Charge battery.
ER3	Over Temperature	Battery is too hot. Consider ambient temperature, insulation and adequate spacing between batteries.
ER4	Under Temperature	Battery is too cold. Consider ambient temperature and insulation. Check heating status as the battery may require additional time to reach charging temperature.
ER5	Charge Over Current	Adjust charger setpoints to limit below the maximum current specified for the battery model.
ER6	Short Circuit/Discharge Overcurrent	Adjust charger setpoints to limit below the maximum current specified for the battery model. Use caution on install to avoid accidentally short circuiting the battery.
ER7	Imbalance	If repeated imbalance occurs, reduce charger setpoints and leave at CV voltage to rebalance cells.
ER8	Switch Over Temperature	Potentially address cooling/insulation, current, and external temperature. If this continues at currents below specification, contact Technical Support.

APPENDIX B: BMS PROTECTION SUMMARY REFERENCE

CODE	PROTECTION	RESET METHOD	COMMENTS
Cell/Pack Overvoltage	Charge Interruption	Automatic reset after time delay or discharge.	If occurring more than 3 times in 2 minutes, discharge is required.
Cell/Pack Undervoltage	Discharge Interruption	Automatic reset after time delay or charge.	If occurring more than 3 times in 2 minutes, charge is required.
Extended Pack Undervoltage (Stored While Empty)	Battery Cannot Be Recovered	Always charge Rolls LFP drop-in batteries within 72 hours of full discharge.	
Pack Overcurrent or Short Circuit	Charge & Discharge Interruption	Automatically reset after time delay.	If occurring more than 3 times in 2 minutes, charge is required.
High temperature at BMS or Cell*	Charge & Discharge Interruption	Automatically reset after cooling.	BMS will display alarm when approaching disconnect.
Low temperature at BMS or Cell*	Charge Interruption	Automatically reset after warming.	BMS will display alarm when approaching disconnect.
Extreme low temperature at BMS or Cell	Charge & Discharge Interruption	Automatically reset after warming.	BMS will display alarm when approaching disconnect.
Secondary Overcurrent Protection (G-Series & S-Series only)	Charge & Discharge Interrupted. External fuse is blown.	Replace fuse.	Secondary protection is also recommended for all Rolls R-Series LFP drop-in batteries.

APPENDIX C: ROLLS GOLF & LIGHT EV LFP BATTERY SOC INDICATOR INSTALLATION GUIDE

OVERVIEW

This document provides installation and operating instructions for the state of charge (SOC) and voltage indicator supplied with select Rolls G-Series golf and light EV LFP lithium batteries equipped with CAN bus output port. This SOC display uses CAN bus communication to relay state of charge and error data in a small footprint with integrated TFT display.

PHYSICAL DESCRIPTION


The supplied SOC indicator operates by connecting the supplied RJ45 cable to the CAN bus port on the battery and the MOLEX connector on the SOC indicator. The SOC indicator is designed to be easily mounted in the dash of the cart or light EV in a drilled **52mm** hole.



The display on the SOC indicator will change colour based on the SOC estimate and error indication provided by the BMS:

	Green Display 70-100% SOC		Red Display 0-20% SOC
	Yellow Display 20-70% SOC		ERRORS: Red wrench: Controller failure Yellow wrench: BMS comms failure

PINOUT



PIN	PIN DEFINITION
1	Debug/not used
2	Key Switch
3	NC Relay Positive (Red)
4	NC Relay Negative (Black)
5	Power Negative
6	Hour Meter Trigger
7	Power Positive
8	Power Negative
9	CAN - L (Yellow)
10	CAN - H (Green)
11	N/C

NC Relay will trigger on reported SOC of 0 and can support a current of up to 1A.

INSTALLATION OF THE SOC INDICATOR

Installing and connecting the SOC indicator is a simple procedure.

STEPS:

1. Choose the desired location on the dash of the golf cart or light EV vehicle. Ensure there are no obstructions or wiring in the area, and the location allows sufficient space for the monitor and cabling to be installed.
2. Drill a hole (52mm) where the SOC indicator will be installed.
3. Remove the two screws holding the mounting brace on the back of the SOC indicator. Insert the SOC indicator into the drilled hole and reattach the mounting brace with the two arms facing forward, firmly securing it against the rear of the mounting surface.

NOTE: as the thickness of the mounting surface (dash) may vary, the two arms of the mounting brace may be adjusted or bent outward slightly to securely fasten the SOC indicator in place.


4. Connect the two pin connectors on the supplied RJ45 cable to the rear of the SOC indicator and the CAN port of the battery.
5. Power on the battery.

INSTALLATION OF AN IN-LINE POWER SWITCH

When installing the SOC indicator supplied with select Rolls golf & light EV LFP lithium batteries, users may prefer to also install an in-line power switch to conveniently disconnect power to the SOC indicator. This will avoid any latent draws on the battery when the cart sits idle or is in storage.

PHYSICAL DESCRIPTION

The supplied SOC indicator operates by connecting the supplied RJ45 cable to the CAN bus port on the battery and the MOLEX connector on the SOC indicator. The SOC indicator is designed to be easily mounted in the dash of the cart or light EV in a drilled **52mm** hole.



Installation and connection of the in-line switch can be easily accomplished by following the steps outlined below.

To complete the installation, the following tools and supplies will be required:

- Wire stripper
- Utility knife
- Terminal crimper/soldering iron/Screw terminal
- Heat shrink/electrical tape/adhesive

STEPS:

NOTE: Complete the following installation steps with the wiring to the battery **disconnected**. Wiring on the battery contains live 51.2V DC voltage. Although a shock would not be harmful, it may damage equipment or cause discomfort.

1. The first step in the installation process is to choose the desired location to install the SOC indicator and the in-line switch on the vehicle.
2. Drill a hole (52mm) in the desired location for the SOC indicator. Do not place the SOC indicator in the hole until all wiring has been completed.

Reminder: Ensure there are no obstructions or wiring in the area, and the location allows sufficient space for the monitor and cabling to be installed.

3. After choosing an installation location for the SOC indicator, run the cable from the battery compartment to the desired location. Near the hole, locate and mark a point on the cable where the in-line switch will be installed. This will be the point where you make a cut into the insulation of the wiring.


Choosing a point that allows ample wire into the switch, without extending the internal wires, will make for the quickest job with least opportunity for error.

4. Remove the external jacket from the cable using wire strippers with a 2.6mm (approximate) opening. Be especially careful not to cut the internal wiring or puncture the insulating material.




5. At the approximate location where you will be installing the switch, make two cuts in the using the wire strippers (2.6 mm) approximately 10cm apart on the black insulation of the cable, again, ensuring not to cut the internal wiring or puncture the insulating material.
6. If the insulating material is damaged, this may be fixed with electrical tape. However, making another incision further along the cable is best to be able to do this effectively.
7. Separate the black insulation at your cut points by rotating the black insulation against itself to separate the two parts.
8. Set a utility knife to expose approximately 1-2 millimeters of the blade or use snips to carefully cut into the black insulation parallel to the wire. Be sure not to impact the internal wires. Cut about one centimeter of the black insulation along the wire.

9. Separate this with your fingers and pull on the black insulation to continue tearing down until you've reached your second cut and can remove the black insulation.



10. You should now have green, yellow, red, and black wires exposed without any damage to any of coloured insulation.
11. Find the middle of the exposed red wire and cut it. Strip back enough insulation on either side of the red wire to make your connections to your switch.




12. Follow the instructions for connecting and installing the chosen in-line switch, connecting the red wires to the switch accordingly. Depending on the type of switch used, it may be necessary to install the switch before connecting the wires.
13. Once the in-line switch has been connected, you may now test the connection and attach the RJ45 cable to the battery and the two pin connectors to the rear of the SOC indicator.



14. Power on the battery and put the switch in the closed (on) position to ensure your SOC indicator turns on. Turn off your switch and check that the SOC indicator also turns off. The test is now complete.
15. Power off the battery, disconnect the RJ45 cable from the battery, and disconnect the two pin connectors from the mount SOC indicator.
16. Remove the two screws holding the mounting brace on the back of the SOC indicator. Position the monitor in the drilled hole and reattach the mounting brace with the two arms facing forward, firmly securing it against the rear of the mounting surface.

NOTE: as the thickness of the mounting surface (dash) may vary, the two arms of the mounting brace may be adjusted or bent outward slightly to securely hold the monitor in place.



17. Reconnect the two pin connectors in the SOC indicator. Reconnect the RJ45 cable to battery. Power on the battery. The installation is now complete.



CONTACTS

Surrette Battery Company Ltd.
58 Lisgar Street
Springhill, Nova Scotia, Canada
B0M 1X0

PHONE:

1 902 597 3767 (local)
1 800 681 9914 (toll free)

CUSTOMER SERVICE:

1 902 597 4005
customerservice@rollsbattery.com

SALES:

1 902 597 3767 (local)
1 800 681 9914 (toll free)
sales@rollsbattery.com

TECHNICAL SERVICE:

1 902 597 3767 (phone)
1 800 681 9914 (toll free)
support@rollsbattery.com

TECHNICAL SUPPORT TICKET:

support.rollsbattery.com

NOTES:

[illegible]

Rolls

BATTERY ENGINEERING

BY SURRETTE BATTERY COMPANY

ROLLSBATTERY.COM